



TAMIL NADU FIRE AND RESCUE SERVICES
FORM OF FIRE SERVICE LICENCE

Under Section 13 of the Tamil Nadu Fire Service Act No: 40 of 1985 and
with Tamil Nadu Fire Service Rules 1990 – Appendix – III

Office of the District Officer,
TamilNadu Fire & Rescue Services,
Karur District, Karur.
PH-04324 240408.

L.DIS.NO:225/C1/2025 (SWP T.No:250291)

Date :22.01.2025

(Ref No: 30/V/2025 / Inspected By: S.O. PUGALUR Date of Inspection: 20.01.2025)

Licence is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985, for RUNNING A COLLEGE OF SCIENCE AND MANAGEMENT in the Name of VALLUVAR COLLEGE OF SCIENCE AND MANAGEMENT within the Jurisdiction of KADAIYUR PUNCHAYAT at the premises S.F.NO:225/1.2, NH-7, KARUR-MADURAI BYE PASS ROAD, KADAIYUR VILLAGE, PUTHAMPUR POST, ARAVAKURICHI TALUK, Karur District subject to the conditions noted thereon and such other conditions as may be prescribed.

CONDITION

1. The Following fire extinguishers installed in the premise should be maintained properly.
Fire Extinguishers- ABC-4kg-32Nos, Fire buckets – 6 Nos.
 2. All Fixed Installations should be maintained properly as per National Building Code of India -2016 (Part-IV Fire & Life Safety)
 3. Register of Fire Extinguisher and Register of Mock drill should be maintained as per form II & III Respectively.
 4. If any extension or alteration is made in the existing building and also for changing of present business will also apply & get separate permission.
 5. Elementary fire fighting training should be given to the employee's from Fire and Rescue Service Department.
 6. A Board bearing the phone number of the Fire & Rescue Station Number should be displayed in the premises.
 7. House keeping should be neat and clean.
 8. This License is valid for one year from the date issue.
 9. In Compliance to section 3.5 of BIS 12459:1988- code of practice for fire safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.
- (Office Seal with Date)



[Signature]
District Officer,
Fire and Rescue Services,
Karur District, Karur.
[Signature]
22/1/25
[Signature]
22/1/25

To,
M/S. Valluvar College of Science and Management,
Karur-Madurai Highway,
Puthampur Post, Kadaiyur Village,
Aravakurichi Taluk, Karur District.

Copy To: Deputy Director, Fire & Rescue Services, Central Region, Tiruchirappalli-620 001.